

Декларация за съответствие

Долуподписаният "Сектрон ООД"

бул. "Г. М. Димитров" №52

декларирам на собствена отговорност, че продуктът: Адресируема сирена
/ НОСНІКІ, СНQ-WS2 /

(наименование и търговска марка, тип или модел, № на партидата, извадката (пробата) или серията, евентуално
произход и брой на екземплярите)

за който се отнася тази декларация, е в съответствие със следния(те) стандарт(и),
техническо одобрение (ТО) или друг(и) нормативен(ни) акт(актове)

EN 54: част 3: 2001

(наименование и/или номер и дата на издаване на стандарта (тите), ТО или друг(ите) нормативен (и) акт (актове)

и в съответствие с Наредбата за съществени изисквания и оценяване съответствието на
строителните продукти съществени изисквания за безопасност на други наредби за
оценяване на съответствието.....

име (наименование), адрес и идентификационен номер на упълномощено лице за
оценяване на съответствието (когато се изисква).....

номер и дата на издадени сертификати, технически одобрения и протоколи от изпитване
(в случай, че има такива)

специфични изисквания, свързани с употребата на продукта (указания за проектиране,
изпълнение и експлоатация) (може да се приложат отделно към декларацията)
.....

година на поставяне на маркировката, "СО" 07.12.2006г.

Декларирам, че ми е известна отговорността, която нося съгласно чл. 313 от НК.

София, 15.06.2010 г.

Ст. Димитров, Маркетинг Мениджър

.....

.....

(място и дата на издаване)

(фамилия, длъжност и подпис
на производителя или на негов представител)



Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 164h

HOCHIKI EUROPE (UK) LIMITED

Products

LPCB Ref. No.

CHQ-WS2 Loop powered wall sounder (YBN-R/3 and YBO-R/SCI bases)

164h/02

Note:

1. Meets the requirements of EN 54-3 at the following tones:
H1 - 925/628 at 2Hz
H4 - French 554: 100ms / 440: 400ms
H5 - Swedish 660: 150ms / Off: 150ms
8 - Whoop 500-1200 3s/0.5s
12 - Sweep 800/970 at 1Hz
15 - Sweep 2400-2850 at 1Hz
17 - 970:ISO8201 0.5s
18 - 2850:ISO820 0.5s

CHQ-WS2(WHT) – Loop powered wall sounder - white version
(YBN-R/3 and YBO-R/SCI bases)

164h/02

Note:

1. Meets the requirements of EN 54-3 at the following tones:
H1 - 925/628 at 2Hz
H4 - French 554: 100ms / 440: 400ms
H5 - Swedish 660: 150ms / Off: 150ms
8 - Whoop 500-1200 3s/0.5s
12 - Sweep 800/970 at 1Hz
15 - Sweep 2400-2850 at 1Hz
17 - 970:ISO8201 0.5s
18 - 2850:ISO820 0.5s

For details of Cross-Listed products and alternative branding please see page 18.

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please
visit our website www.RedBookLive.com or contact us.

Signed on behalf of LPCB

Page 6 of 18

Date of Issue 18 December 2009


Issue No. 05

Name: P STEVENS

LPCB is part of BRE Global Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions
and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 164h

HOCHIKI EUROPE (UK) LIMITED

Products

LPCB Ref. No.

CHQ-WS2/W Loop powered wall sounder- weatherproof version
(YBN-R/3, YBO-R/SCI and WS2-WPK base)

164h/02

Note:

1. Meets the requirements of EN 54-3 at the following tones:
H1 - 925/628 at 2Hz
H4 - French 554: 100ms / 440: 400ms
H5 - Swedish 660: 150ms / Off: 150ms
8 - Whoop 500-1200 3s/0.5s
12 - Sweep 800/970 at 1Hz
15 - Sweep 2400-2850 at 1Hz
17 - 970:ISO8201 0.5s
18 - 2850:ISO820 0.5s

YBO-BSB Loop powered base sounder and beacon
(YBN-R/3 and YBO-R/SCI bases)

164h/03

Note:

1. The beacon function of this device is not included in the scope of this approval
2. Meets the requirements of EN 54-3 at the following tones:
1 - 925 Hz : 250 ms / 628 Hz : 250 ms
2 - 925 Hz Continuous
3 - 628 Hz Continuous
4 - (French) 554 Hz : 100 ms / 440 Hz : 400 ms
5 - (Swedish) 660 Hz : 150 ms / Off : 150 ms
6 - 925 Hz : 150 ms / Off : 600 ms
7 - 670 Hz : 250 ms / 845 Hz : 370 ms
8 - Whoop 500 Hz - 1200 Hz : 3000 ms / Off : 500 ms
9 - 1200 Hz : 500 ms / 500 Hz : 500 ms
10 - 970 Hz : 500 ms / Off : 500 ms
11 - Sweep 800 Hz - 970 Hz over 140 ms (7 Hz)

Continued . . .

For details of Cross-Listed products and alternative branding please see page 18.

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please
visit our website www.RedBookLive.com or contact us.

Signed on behalf of LPCB

Name: P STEVENS

Page 7 of 18

Date of Issue 18 December 2009

Issue No. 05

LPCB is part of BRE Global Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions
and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 164h

HOCHIKI EUROPE (UK) LIMITED

- 12 - Sweep 800 Hz - 970 Hz over 1000 ms (1 Hz)
- 13 - Sweep 800 Hz - 970 Hz over 20 ms (50 Hz)
- 14 - Sweep 2400 Hz - 2850 Hz over 140 ms (7 Hz)
- 15 - Sweep 2400 Hz - 2850 Hz over 1000 ms (1 Hz)
- 16 - Sweep 300 Hz - 1200 Hz over 1000 ms (1 Hz)
- 17 - ISO8201 : 970 Hz : 500 ms
- 18 - ISO8201 : 2850 Hz : 500 ms
- 19 - 800 Hz : 250 ms / 970 Hz : 250 ms
- 20 - 2850 Hz Continuous
- 21 - 2400 Hz : 250 ms / 2850 Hz : 250 ms
- 22 - 800 Hz : 500 ms / 970 Hz : 500 ms
- 23 - 2850 Hz : 500 ms / Off : 500 ms
- 24 - 925 Hz : 250 ms / Off : 1000 ms
- 25 - 970 Hz Continuous
- 26 - 660 Hz : 1800 ms / Off : 1800 ms
- 27 - 660 Hz : 6500 ms / Off : 13000 ms
- 28 - 660 Hz Continuous
- 29 - 554 Hz : 500 ms / 440 Hz : 500 ms
- 30 - 660 Hz : 500 ms / Off : 500 ms
- 31 - 2850 Hz : 150 ms / Off : 100 ms
- 32 - Sweep 2400 Hz - 2850 Hz over 20 ms (50 Hz)
- 33 - Sweep 800 Hz - 970 Hz over 500 ms (2 Hz)
- 34 - 988 Hz : 250 ms / 645 Hz : 250 ms
- 35 - 510 Hz : 250 ms / 610 Hz : 250 ms
- 36 - Sweep 800 Hz - 970 Hz over 110 ms (9 Hz)
- 37 - Sweep 800 Hz - 970 Hz over 330 ms (3 Hz)
- 38 - 845 Hz Continuous
- 39 - 970 Hz : 1000 ms / Off : 1000 ms
- 40 - 800 Hz : 150 ms / 970 Hz : 150 ms
- 41 - Sweep 2400 Hz - 2850 Hz over 110 ms (9 Hz)
- 42 - Sweep 2400 Hz - 2850 Hz over 330 ms (3 Hz)

Continued . . .

For details of Cross-Listed products and alternative branding please see page 18.

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please
visit our website www.RedBookLive.com or contact us.

Signed on behalf of LPCB

Name: P STEVENS

Page 8 of 18

Date of Issue 18 December 2009

Issue No. 05

LPCB is part of BRE Global Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions
and is maintained and held in force through regular surveillance activities.