

Декларация за съответствие

Долуподписаният "Сектрон ООД"

бул. "Г. М. Димитров" №52

декларирам на собствена отговорност, че продуктът: Аналогов адресируем контролен панел

/Kentec, Syncro 2, 4 кръга/

(наименование и търговска марка, тип или модел, № на партидата, извадката (пробата) или серията, евентуално произход и брой на екземплярите)

за които се отнася тази декларация, е в съответствие със следния(те) стандарт(и), техническо одобрение (ТО) или друг(и) нормативен(ни) акт(актове)

EN 54: част 2: 1998

EN 54: част 4: 1998

(наименование и/или номер и дата на издаване на стандарта (тите), ТО или друг(ите) нормативен (и) акт (актове)

и в съответствие с Наредбата за съществените изисквания и оценяване съответствието на строителните продукти съществени изисквания за безопасност на други наредби за оценяване на съответствието.....

име (наименование), адрес и идентификационен номер на упълномощено лице за оценяване на съответствието (когато се изисква).....

номер и дата на издадени сертификати, технически одобрения и протоколи от изпитване (в случай, че има такива)

специфични изисквания, свързани с употребата на продукта (указания за проектиране, изпълнение и експлоатация) (може да се приложат отделно към декларацията)

година на поставяне на маркировката, "СО" 25.10.2007г.

Декларирам, че ми е известна отговорността, която нося съгласно чл. 313 от НК.

София, 15.06.2010 г.

.....

(място и дата на издаване)

Ст. Димитров /Маркетинг Менеджър

.....

(фамилия, длъжност и подпис
на производителя или на негов представител)



Kitemark[®] Licence



No. KM 73505

BSI hereby grants to:

**Kentec Electronics Limited
Units 25-27 Fawkes Avenue
Questor
Dartford
DA1 1JQ
United Kingdom**

In respect of:

**BS EN 54-2 & BS EN 54-4
Fire Panel & Power Supplies**

the right and Licence to use the Kitemark in accordance with the Kitemark Licence Conditions of Contract governing the use of the Kitemark, as may be updated from time to time by BSI, and as approved by the Registrar under the Trade Marks Act 1994 (the "Conditions"). All defined terms in this Licence shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Licence provided at or from the above address.

For and on behalf of BSI:

David Ford, Director, Healthcare and Testing Services



First granted: 5 Aug 2003

Date: 15 Feb 2010

Page: 1 of 6



003

raising standards worldwide[™]

This licence remains the property of BSI and shall be returned immediately upon request. This licence does not expire.
To check its validity call +44 (0)8450 765600



Kitemark[®] Licence



No. KM 73505

Kentec Electronics Limited

Dartford

BS EN 54 Part 2: 1998 and BS EN 54 Part 4: 1998

Model	Type
Syncro	2 Loop Analogue Addressable Control and Indicating Equipment
Syncro	2 Loop 16 Zone Analogue Addressable Control and Indicating Equipment
Syncro	2 Loop 48 Zone Analogue Addressable Control and Indicating Equipment
Syncro	2 Loop 96 Zone Analogue Addressable Control and Indicating Equipment
Syncro	4 Loop Analogue Addressable Control and Indicating Equipment
Syncro	4 Loop 16 Zone Analogue Addressable Control and Indicating Equipment
Syncro	4 Loop 48 Zone Analogue Addressable Control and Indicating Equipment
Syncro	4 Loop 96 Zone Analogue Addressable Control and Indicating Equipment

Certified for use with Apollo xplorer, XP95, Discovery, Hochiki ESP and Argus Vega fire detection and alarm devices and in both Flush and Surface mountable enclosure types.

The Syncro range of CIE are certified with an integral S232SYN printer, enable key switch and integral or external PSE.

Certified for use with the following optional boards:

S545 4 Way Zone Card
S546 6 Way Sounder Card
S547 8 Way Relay Card
S555 Network Card
S560 16 Channel I/O Card

First granted: 5 Aug 2003

Date: 15 Feb 2010

Page: 3 of 6

raising standards worldwide[™]

This licence remains the property of BSI and shall be returned immediately upon request. This licence does not expire.
To check its validity call +44 (0)8450 765600



Kitemark[®] Licence



No. KM 73505

Kentec Electronics Limited

Dartford

Options with requirements

Certified with the following options with requirements from BS EN 54 Part 2: 1998:

- Output to fire alarm devices (clause 7.8)
- Output to fire alarm routing equipment (clause 7.9)
- Output to fire protection equipment (clause 7.10)
- Delays to outputs (clause 7.11)
- Coincidence detection (clause 7.12)
- Fault signals from points (clause 8.3)
- Disabling of addressable points (clause 9.5)
- Test condition (clause 10)

The following BSI Test Reports refer:

244/4479447, 407002, 222/4479444, 288/4479443, 228/4479445
228/4716716, 244/4479477

First granted: 5 Aug 2003

Date: 15 Feb 2010

Page: 4 of 6

raising standards worldwide[™]

This licence remains the property of BSI and shall be returned immediately upon request. This licence does not expire.
To check its validity call +44 (0)8450 765600

