

Декларация за съответствие

Долуподписаният "Сектрон ООД"

бул. "Г. М. Димитров" №52

декларирам на собствена отговорност, че продуктът: Аналогов адресируем контролен панел

/Kentec, Syncro AS, Syncro AS Lite, Syncro AS Marine/

(наименование и търговска марка, тип или модел, № на партидата, извадката (пробата) или серията, евентуално произход и брой на екземплярите)

за които се отнася тази декларация, е в съответствие със следния(те) стандарт(и), техническо одобрение (ТО) или друг(и) нормативен(ни) акт(актове)

EN 54: част 2: 1997 +A1 +AC

EN 54: част 4: 1998 +A1 +A2

(наименование и/или номер и дата на издаване на стандарта (тите), ТО или друг(ите) нормативен (и) акт (актове)

и в съответствие с Наредбата за съществените изисквания и оценяване съответствието на строителните продукти съществени изисквания за безопасност на други наредби за оценяване на съответствието.....

име (наименование), адрес и идентификационен номер на упълномощено лице за оценяване на съответствието (когато се изисква).....

номер и дата на издадени сертификати, технически одобрения и протоколи от изпитване (в случай, че има такива)

специфични изисквания, свързани с употребата на продукта (указания за проектиране, изпълнение и експлоатация) (може да се приложат отделно към декларацията)

година на поставяне на маркировката, "СО" 25.10.2007г.

Декларирам, че ми е известна отговорността, която нося съгласно чл. 313 от НК.

София, 15.06.2010 г.

Ст. Димитров /Маркетинг Менеджър

(място и дата на издаване)

(фамилия, длъжност и подпис на производителя или на негов представител)



Kitemark[®] Licence



No. KM 73505

Kentec Electronics Limited

Dartford

BS EN 54-2: 1997 + A1 + AC and BS EN 54-4: 1998 + A1 & A2

Model	Type
Syncro AS	1 Loop, 16 Zone Analogue Addressable Control and Indicating Equipment
Syncro AS Lite	1 Loop, 16 Zone Analogue Addressable Control and Indicating Equipment
Syncro AS Marine	1 Loop, 16 Zone Analogue Addressable Control and Indicating Equipment
Syncro AS	2 Loop, 16 Zone Analogue Addressable Control and Indicating Equipment
Syncro AS Marine	2 Loop, 16 Zone Analogue Addressable Control and Indicating Equipment

Certified for use with Apollo xplorer, XP95, Discovery, Hochiki ESP and Hochiki America and Argus Vega fire detection and alarm devices and in both Flush and Surface mountable enclosure types.

Options with requirements

Certified with the following options with requirements from BS EN 54 Part 2: 1997:

- Output to fire alarm devices (clause 7.8)
- Delays to outputs (clause 7.11)
- Type C dependency (clause 7.12.3)
- Fault signals from points (clause 8.3)
- Disabling of addressable points (clause 9.5)
- Test condition (clause 10)

First granted: 5 Aug 2003

Date: 15 Feb 2010

Page: 5 of 6

raising standards worldwide[™]

This licence remains the property of BSI and shall be returned immediately upon request. This licence does not expire.
To check its validity call +44 (0)8450 765600



Kitemark[®] Licence



No. KM 73505

Kentec Electronics Limited

Dartford

Certified for use with the following optional boards:

- S545 4 Way Zone Card
- S546 6 Way Sounder Card
- S547 8 Way Relay Card
- S555 Network Card
- S560 16 Channel I/O Card

The following BSI Test Reports refer:

244/7000367 1 of 2, 244/7000367 2 of 2, 244/7138115, 222/7000365, 228/4944547 1 of 3,
228/4944547 2 of 3, 703002 and 228/7161856
244/7376099

BS EN 54 Part 4: 1998

Model	Type
ENK15400 01	4 Amp Standalone Switch Mode Power Supply Equipment incorporating ENS400 chassis PSE

The following BSI Test Reports refer:

244/4463486, 222/4463483, 288/4463487 and 228/4463485

First granted: 5 Aug 2003

Date: 15 Feb 2010

Page: 6 of 6

raising standards worldwide[™]

This licence remains the property of BSI and shall be returned immediately upon request. This licence does not expire.
To check its validity call +44 (0)8450 765600

