CCA

NOTIFICATION OF TEST RESULTS (PERMANENT DOCUMENT MC-10)

INSTRUCTION

(This is the heading of the notification. Name of the body which has issued the NTR is given at the bottom only)

ProductFIRE ALARM PANEL
tested by request of PARADOX HELLAS S.A.
manufactured at (name and place) PARADOX HELLAS S.A.,
3 KORINTHOU STR. METAMORFOSI, GR-14451, GREECE
Rating and principal characteristics. 195-255Vac, 85W, 50Hz
Preliminary visit carried out by ELOT S.A.
Trade mark (if any)
Additional information (if any). Applicable product standard EN 54-2 & EN 54-4
A sample of the product has been tested and found to be in conformity with the
current HD/EN and equivalent national standard,(number and edition).
as shown in the test report (reference N°)57.03.1/3683.01

This Notification of Test results is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standard.

This Notification of Test Results has been established by a body which participates in the CCA of 11th September 1973 as amended on 29th March 1983. Any other body participating in the CCA will take this Notification as a basis for granting a national mark of conformity or a national approval as specified in the CCA, as long as the standard referred to above is still in force in the country of that body.

51.2120107 51.2120107 57.24
37.74
٧A

(Only here the full name is to be given)

Name of the body - signature: